




**ECO Visit To Emerald Isle  
CommScope Bray  
March 5<sup>th</sup> 2015**




**The Modular Data Centre  
....Economic, Technical and Efficiency Models**

- Willie O'Connell, M.D. DCoD Europe

- **Modular Designs**
- **Flexibility**



- **Efficiency**
- **Economic Advantages**



## Typical Container Design:

Fixed, inflexible configurations not optimized for Data Center equipment, poor air-handling, energy inefficient.


Relatively low cost

Mobile

Robust

# Modular Designed Purpose-Built Data Centres

COMMScope®



**Combining the Flexibility of Traditional  
with the Time-to-Value of Modular**





## Building Blocks

- DCU 01 (1 Rack)
- DCU 04 (4 Racks)
- DCU 10 (10 Racks)
- DCU 20 (20 Racks)
- DCU 30 (30 Racks)


## Universal Features

- 5 to 35 kW per Rack
- 3<sup>rd</sup> Party Racks, Cabinets, White Space
- TIER, Mechanical, Electrical, Security, Fire, Core Infrastructure Customizable

## Vestibule

- Standard and Large
- Adjoining white space for:  
(optional infrastructure; UPS; Switch Gear; Patch Panels; Technician Workstations)

# CommScope DCU-04, 4 Rack Data Center






**Air Mixing Chamber /  
 Electrical & Mechanical Section**

**IT Section  
 Ample Hot and Cold Isle Working Space**

# CommScope DCU

## Expandability – Seamless Hot/Cold Aisles









## CommScope DCU-30 (30 Racks)

COMMScope®



- Universal Cooling Shown
  - Outside Air Plus Evaporative
  - With Chilled Water Or DX

# CommScope DCU-30 – Side and Plan Views















Class	IT Equipment Type	Environment Control (dust and particulates filtering)
A1	Enterprise servers and critical data storage	Tightly controlled MERV 6 + MERV 14 new air MERV 10 Air recycled
A2	Enterprise servers and data storage	Controlled MERV 6 + MERV 14 new air MERV 10 Air recycled
A3	Other servers and data storage, workstations	Same as A2
A4	Other servers and storage, workstations	Same as A2





# Agility - Flexibility - Manageability



# Global Deployments






## Highly Efficient Proprietary Evaporative Cooling and Re-Heating system


- Direct Outside Air System
- Multi Stage Air Filtration and Moisture Elimination
- Filtration Options Based on Environment
- Multi-Stage Redundant Evaporative Cooling
- Proprietary Air Mixing Chamber
- Overall System Eliminates typical DX or Chilled Water Infrastructure
- Requires little water when used. No chemical waste
- Optional Integrated DX or Chilled Water Coils for supplemental Peak cooling and 100% recirculation with no outside air IF required

**Psychrometric chart**  
SI metric units, sea level  
barometric pressure – 101.3 kPa




Class	Recommended Working temperatures	Allowable Working Temperatures	Relative Humidity
A1	2004: 20 to 25 ° C 2008: 18 to 27 ° C 2011: 18 to 27 ° C	15 to 32 ° C	2004: 40 to 55 %Hr 2008: max 60 %Hr 2011: 8 to 80 %Hr
A2	Idem	10 to 35 ° C	2008: 20 to 80 %Hr 2011: 8 to 80 %Hr
A3	Idem	5 to 40 ° C	8 to 85 %Hr
A4	Idem	5 to 45 ° C	8 to 90 %Hr

## How **EVAPORATIVE COOLING** works



## THE PRINCIPLE OF ADIABATIC COOLING





connect disconnect
LOCAL CONNECT °C
🔴

**REAL TIME**

DOORS

FAN DATA

POWER MONITOR

VIEW

PSYCHROMETRIC CHART

LOG DATA

SET POINTS

TEMPERATURES

OUTSIDE AIR	DB	0 °C	A																																																							
	RH	0.0%																																																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>MIN</th> <th>MAX</th> <th>AVERAGE</th> </tr> </thead> <tbody> <tr> <td style="background-color: #e0f0ff;">COLD AISLE</td> <td>DB</td> <td>0 °C</td> <td>0 °C</td> <td>0 °C</td> </tr> <tr> <td></td> <td>RH</td> <td>0.0%</td> <td>0.0%</td> <td>0.0%</td> </tr> <tr> <td style="background-color: #e0f0ff;">HOT AISLE</td> <td>DB</td> <td>0 °C</td> <td>0 °C</td> <td>0 °C</td> </tr> <tr> <td style="background-color: #e0f0ff;">ΔT</td> <td></td> <td>0 °C</td> <td>0 °C</td> <td style="background-color: yellow;">0 °C</td> </tr> <tr> <td style="background-color: #e0f0ff;">ΔT SET POINT</td> <td></td> <td>0 °C</td> <td></td> <td></td> </tr> <tr> <td style="background-color: #e0f0ff;">FAN OUTPUT</td> <td></td> <td>0 %</td> <td></td> <td></td> </tr> <tr> <td style="background-color: #e0f0ff;">AIRFLOW</td> <td></td> <td colspan="3">0.00 m3/s</td> </tr> <tr> <td style="background-color: #e0f0ff;">AIRFLOW SP</td> <td></td> <td colspan="3"></td> </tr> <tr> <td style="background-color: #e0f0ff;">VESTIBULE TEMP</td> <td></td> <td colspan="3">0 °C</td> </tr> <tr> <td style="background-color: #e0f0ff;">VESTIBULE HEATER</td> <td></td> <td colspan="3">0 %</td> </tr> </tbody> </table>						MIN	MAX	AVERAGE	COLD AISLE	DB	0 °C	0 °C	0 °C		RH	0.0%	0.0%	0.0%	HOT AISLE	DB	0 °C	0 °C	0 °C	ΔT		0 °C	0 °C	0 °C	ΔT SET POINT		0 °C			FAN OUTPUT		0 %			AIRFLOW		0.00 m3/s			AIRFLOW SP					VESTIBULE TEMP		0 °C			VESTIBULE HEATER		0 %		
	MIN	MAX	AVERAGE																																																							
COLD AISLE	DB	0 °C	0 °C	0 °C																																																						
	RH	0.0%	0.0%	0.0%																																																						
HOT AISLE	DB	0 °C	0 °C	0 °C																																																						
ΔT		0 °C	0 °C	0 °C																																																						
ΔT SET POINT		0 °C																																																								
FAN OUTPUT		0 %																																																								
AIRFLOW		0.00 m3/s																																																								
AIRFLOW SP																																																										
VESTIBULE TEMP		0 °C																																																								
VESTIBULE HEATER		0 %																																																								

STATUS/ALARMS

DOORS	FAN DOORS
LIGHT SWITCH	LIGHTS
UPS PLC STATUS	
WATER LEAK	
FAN STATUS	
DAMPER STATUS	
FIRE PREALARM	FIRE ALARM
GAS DISCHARGE	
FILTER 1	FILTER 2
FILTER 3	FILTER 4

POWER MONITOR

	CURRENT	RUNNING
TOTAL	0.0 kW	0 HRS
SERVER	0.0 kW	0.0kW/hr
PUE	0.000	0.000

EVAP. COOL.

STEP 1
STEP 2
STEP 3
STEP 4



R80-VEE- Ver.: 11.8.0.2

connect disconnect LOCAL CONNECT °C

**REAL TIME**

**DOORS**

**FAN DATA**

**POWER MONITOR**

**VIEW**

**PSYCHROMETRIC CHART**

**LOG DATA**

**SET POINTS**

**SET POINTS** **OPERATING MODE**

**OPERATING RANGE**

	MINIMUM	MAXIMUM
TEMPERATURE	<input type="text"/>	<input type="text"/>
RELATIVE HUMIDITY	<input type="text"/>	<input type="text"/>

**OPERATING PARAMETERS**

MIN. FAN OUTPUT  %

VESTIBULE SP

**FAN PID PARAMETERS**

- (0) AVERAGE DELTA T SETPOINT
- (1) MAX DELTA T (MIN SERVER IN / MAX SERVER OUT)

(0) DELTA T

- (2) DELTA T BASED ON HI/LO TEMP

DELTA T

LO/Hi TEMP SET POINT

- (3) AIR FLOW BASED ON HI/LO TEMP
- (4) MAXIMUM HOT AISLE TEMPERATURE

AIR FLOW

MAX HOT AISLE TEMP SET POINT

UPDATE EDIT


**SOLENOID VALVE TIMER**

Interval  seconds

Steps

EDIT

UPDATE



# Weather/Site Analysis Tools

Know Exactly how a DCU will Perform, Anywhere, Hourly



**NOAA** NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION  
UNITED STATES DEPARTMENT OF COMMERCE



The screenshot shows a software window titled 'Form1' with a 'SELECT SITE' button. Below it is a world map. To the left is a list of countries and stations. In the center, a table lists data for various locations, including columns for 'CITY', 'COUNTRY', 'LAT', 'LONG', 'ELEVATION', 'TIMEZONE', 'WIND DIRECTION', 'WIND SPEED', 'PRECIPITATION', 'RELATIVE HUMIDITY', 'DEW POINT', 'DAYS IN YEAR', 'HOURS IN YEAR', 'MONTHS IN YEAR', 'DAYS IN MONTH', 'HOURS IN MONTH', 'MONTHS IN MONTH', 'DAYS IN DAY', 'HOURS IN DAY', 'MONTHS IN DAY', 'DAYS IN HOUR', 'HOURS IN HOUR', 'MONTHS IN HOUR', 'DAYS IN MINUTE', 'HOURS IN MINUTE', 'MONTHS IN MINUTE', 'DAYS IN SECOND', 'HOURS IN SECOND', 'MONTHS IN SECOND', 'DAYS IN MILLISECOND', 'HOURS IN MILLISECOND', 'MONTHS IN MILLISECOND', 'DAYS IN MICROSECOND', 'HOURS IN MICROSECOND', 'MONTHS IN MICROSECOND', 'DAYS IN NANSECOND', 'HOURS IN NANSECOND', 'MONTHS IN NANSECOND'. Below the table are several line and bar charts showing weather data over time.

## SUMMARY

LOWEST OUTSIDE AIR DRY BULB TEMPERATURE	-10.00 °C
PERCENTAGE OF THE YEAR WITH COLD AISLE DRY BULB TEMPERATURE HIGHER THAN TEH MAXIMUM ALLOWED DRY BULB	0.000 %
PERCENTAGE OF THE YEAR WITH COLD AISLE RELATIVE HUMIDITY HIGHER THAT THE MAXIMUM RH	0.000 %
PERCENTAGE OF THE YEAR WITH COLD AISLE DEW POINT HIGHER THAN THE ALLOWED MAXIMUM DEW POINT	0.377 %
EVAPORATIVE COOLER RUNNING %	0.000 %
EVAPORATIVE COOLER RUNNING TIME	154 hr
TOTAL EVAPORATED WATER	5,403 l/year
TOTAL EVAPORATED WATER (BASED ON 100KW OF IT LOAD)	6,484 l/year
TOTAL WATER CONSUMPTION (BASED ON 100KW OF IT LOAD)	9,726 l/year

## RECOMMENDED OPTIONS


CHILLED WATER OR DX SUPPLEMENTARY COOLING	NO	<p>Unit running in evaporative cooling mode is able to maintain the dry bulb and relative humidity within the limit of the ASHRAE class A1.</p> <p>However it is not able to maintain the dew point below the limit of the A1 class (17°C Outside air conditions 5,6 &amp; 8).</p> <p>If this is not acceptable supplementary cooling (DX or CHILLED WATER) to be sized for 100% of the IT load + 10% for fan heat rejection.</p> <p>Supplementary cooling to run for <b>0.361 % of the year</b> with unit running in full recirculating mode</p>
WATER PIPE HEAT TRACING	YES	
INTERNAL ELECTRIC HEATER	YES	
DAMPERS DEFROST HEATER	YES	Also require actuators with heat tracing
100 MM THICK THERMAL INSULATION	NO	

# Sample Project Layout Design

## 80 to 320 Cabinets (up to 4.8Mw IT HQ)

### ***A modular approach build around the CommScope advance solution DCU-20:***

- 20 Cabinets per module
- Up to 30 kW per cabinet
- Native Free Cooling for low PUE and reduced cost of operation
- Pre-manufactured solution for high quality and fast deployment





# Sample Project Layout design


## Phase 600kw (60 cabs)

### ***A modular approach for a phased investment up to 4 phases***

- First phase construction lead time : max 8 months (not including building permit)
- Time to expand : max 4 months

**Phase 4 / + Second floor**  
**320 cabinets**

**Phase 1 / + Second floor**  
**160 cabinets**



**Phase 3 / Ground floor + first floor**  
**240 cabinets**

**Phase 1 / Ground floor + first floor**  
**80 cabinets**

*These CAPEX estimates are calculated on a Tier 3 + configuration (equivalent to a Tier 4 infrastructure fully redundant 2N without the additional cost of the +1 component per stream)*

Phase 1	7 kW / Rack	10 kW / Rack
Racks	80	80
Power HQ IT	<b>560 kW</b>	<b>800 kW</b>
kW / m <sup>2</sup>	3	4
<b>CAPEX</b>	<b>6 700 000 €</b>	<b>7 250 000 €</b>

Phase 4	7 kW / Rack	10 kW / Rack
Racks	320	320
Power HQ IT	<b>2 240 kW</b>	<b>3 200 kW</b>
kW / m <sup>2</sup>	3	4
<b>CAPEX</b>	<b>16 250 000 €</b>	<b>18 500 000 €</b>

***Moving to a flat land will save the metallic structure estimated at 2,5 M€ (Phase 4)***

***Moving to a standard Tier 3 installation can save 10 to 15 % of the CAPEX figures***

# Sample Project –Cost Per Cabinet

**Currently most Data Centre are designed for 2 to 3 kW Max per m<sup>2</sup> (except HPC DC)**

- 2 kW / m<sup>2</sup> = 5 kW per Cabinet
- 3 kW / m<sup>2</sup> = 7,5 kW per cabinet (defined as high density)

Tier 3 + reference							
k€	KW m <sup>2</sup>	Surface m <sup>2</sup>	Cost m <sup>2</sup>	Racks	Cost Racks	Surface Rack	Power Rack kW
13 000 000	1	1000	13000	400	32 500 €	2,5	2,5
16 000 000	2	1000	16000	400	40 000 €	2,5	5
19 000 000	3	1000	19000	400	47 500 €	2,5	7,5
21 000 000	4	1000	21000	400	52 500 €	2,5	10
24 000 000	5	1000	24000	400	60 000 €	2,5	12,5
27 000 000	6	1000	27000	400	67 500 €	2,5	15

Projet	Sample Project
Racks	CAPEX
320	10 400 000 €
320	12 800 000 €
320	15 200 000 €
320	16 800 000 €
320	19 200 000 €
320	21 600 000 €


Tiers 3 reference							
k€	KW m <sup>2</sup>	Surface m <sup>2</sup>	Cost m <sup>2</sup>	Racks	Cost Racks	Surface Rack	Power Rack kW
11 000 000	1	1000	11000	400	27 500 €	2,5	2,5
13 000 000	2	1000	13000	400	32 500 €	2,5	5
15 000 000	3	1000	15000	400	37 500 €	2,5	7,5
17 000 000	4	1000	17000	400	42 500 €	2,5	10
19 000 000	5	1000	19000	400	47 500 €	2,5	12,5
21 000 000	6	1000	21000	400	52 500 €	2,5	15

Projet	Sample Project
Racks	CAPEX
320	8 800 000 €
320	10 400 000 €
320	12 000 000 €
320	13 600 000 €
320	15 200 000 €
320	16 800 000 €



# Sample Project

## Free & Additional Cooling Hours




# Sample Project

## OPEX Energy / Saving with Free Cooling

Year	2015	2016	2017	2018	2019	2020	2021	2022
<b>Phase</b>	<b>1</b>		<b>2</b>		<b>3</b>		<b>4</b>	
<b>Target IT Load (kW)</b>	<b>800</b>		<b>1600</b>		<b>2400</b>		<b>3200</b>	
<b>IT Load (KW)</b>	<b>400</b>	<b>800</b>	<b>1200</b>	<b>1600</b>	<b>2000</b>	<b>2400</b>	<b>2800</b>	<b>3200</b>
<b>Load rate</b>	<b>50%</b>	<b>100%</b>	<b>75%</b>	<b>100%</b>	<b>83%</b>	<b>100%</b>	<b>88%</b>	<b>100%</b>
<b>PUE Chillers ASHRAE 2008 (Reference)</b>	<b>1,87</b>	<b>1,63</b>	<b>1,69</b>	<b>1,63</b>	<b>1,66</b>	<b>1,63</b>	<b>1,65</b>	<b>1,63</b>
Energy (MWh/Year)	6 552	11 423	17 765	22 846	29 083	34 269	40 471	45 692
Energy Cost (k€/year)	721	1 257	1 954	2 513	3 199	3 770	4 452	5 026
Cumulative Energy Cost (k€)	721	1 977	3 931	6 445	9 644	13 413	17 865	22 891
<b>PUE Free Cooling + Chillers ASHRAE 2011</b>	<b>1,49</b>	<b>1,31</b>	<b>1,35</b>	<b>1,31</b>	<b>1,33</b>	<b>1,31</b>	<b>1,32</b>	<b>1,31</b>
Energy (MWh/Year)	5 221	9 180	14 191	18 361	23 302	27 541	32 377	36 722
Energy Cost (k€/year)	574	1 010	1 561	2 020	2 563	3 030	3 561	4 039
Energy Savings (MWh/year)	1 332	2 243	3 574	4 485	5 782	6 728	8 094	8 970
Cost Savings (k€/year)	146	247	393	493	636	740	890	987
Energy & Cost Savings (%/year)	20,32%	19,63%	20,12%	19,63%	19,88%	19,63%	20,00%	19,63%
Cumulative Energy Cost (k€)	574	1 584	3 145	5 165	7 728	10 758	14 319	18 359
Cumulative Cost Savings (k€)	146	393	786	1 280	1 916	2 656	3 546	4 533
Cumulative Cost Savings (%)	20,32%	19,88%	20,00%	19,86%	19,86%	19,80%	19,85%	19,80%
<b>PUE Free + Evaporative Cooling ASHRAE</b>	<b>1,41</b>	<b>1,23</b>	<b>1,27</b>	<b>1,23</b>	<b>1,25</b>	<b>1,23</b>	<b>1,24</b>	<b>1,23</b>
Energy (MWh/Year)	4 941	8 620	13 350	17 240	21 900	25 860	30 415	34 479
Energy Cost (k€/year)	543	948	1 469	1 896	2 409	2 845	3 346	3 793
Energy Savings (MWh/year)	1 612	2 803	4 415	5 606	7 183	8 410	10 056	11 213
Cost Savings (k€/year)	177	308	486	617	790	925	1 106	1 233
Energy & Cost Savings (%/year)	24,60%	24,54%	24,85%	24,54%	24,70%	24,54%	24,85%	24,54%
Cumulative Energy Cost (k€)	543	1 492	2 960	4 857	7 266	10 110	13 456	17 248
Cumulative Cost Savings (k€)	177	486	971	1 588	2 378	3 303	4 409	5 643
Cumulative Cost Savings (%)	24,60%	24,56%	24,71%	24,64%	24,66%	24,63%	24,68%	24,65%

More than 20 %  
energy saving  
positioned


Up to 3,5 M€ of  
OPEX reduction aver  
7 years



Copyright Apis  
Engineering





True Collocation Hallway, Ample room for Rack and Pallet Movement,  
Doors on IT Rooms and Electrical Panels Not Shown  
Customizable Room for Technician Benches, Patch Panels (MDF/IDF), UPS



# CommScope – Example 120Rack Tier 3 Secure Building




# CommScope – Example 120Rack Tier 3 Secure Building






# CommScope – Example 120Rack Tier 3 Secure Building




# CommScope – Example 120Rack Tier 3 Secure Building





- **TCO**
  - Highly Efficient Data Centers (PPUE) of **1.03 to 1.06**
  - Extremely Competitive Cost PER MW
  - Right Sized Based on Your Requirements
  - Outside Air, Innovative Evaporative Cooling and Re-Heating System
- **Agility and Flexibility**
  - Expandability On Demand
  - CommScope Designs and Delivers Infrastructure
  - Racks, Cabinets, White Space
  - Off-the-Shelf Options or Customized
  - Deployed indoor or outdoor
- **Operational Manageability**
  - Comprehensive Fully Remote DCIM
  - Familiarity
  - Extremely Low Maintenance





**Thank You**

**COMMScope®**